

Dear Water Warriors,

TDS transfer from water (Feed) into water (Reject) is an interesting water treatment technology, where we concentrate the impurities in small quantity of water making rest of the water free of TDS.

Reverse Osmosis is in every process scheme these days and we use software to design and optimize the right RO system.



This issue of 'Waughter', we requested SSr to design a plant for us and explain the way he thinks.

Let's design together.

Nidhi Jain – Civil Engineer

Down the Memory Lane.. IMS Design

Was the First software Sanjeev Srivastava our Lead Technology ever used. Over the years many other software and Knowledge Partners also contributed to improving design thinking: Dupont, Dow, Suez, Toray, CSM, these names became synonym to Reverse Osmosis Know how and all are good.



He still remembers his first design, that was done through complicated Integral Calculus method manually without software. Unfortunately, he does not have hand notes of that and has forgotten manual calculations now.

Defining the Input Required for RO Design?

In order to design a good RO system, one must have all the data mentioned in below table:


Sr No	Description	Unit	Value
1.01	Treated Water Quantity	m ³ /d	600
1.02	RO Operating hours	h	24
1.03	Permeate Flow Rate	m ³ /h	25
1.04	Feed Water Source		Borewell
Feed Water Quality			
2.01	TDS	mg/l	2310
2.02	Conductivity	µS/Cm	3513
2.03	pH	-	7.8
2.04	TSS	mg/l	12
2.05	Turbidity	mg/l	6
2.06	Hardness	mg/l as CaCO ₃	250
2.07	Ca Hardness	mg/l as CaCO ₃	150
2.08	Mg Hardness	mg/l as CaCO ₃	100
2.09	Na+K	mg/l	By Calculation
2.10	Chloride	mg/l as Cl	700
2.11	Sulphate	mg/l as SO ₄	135
2.12	Nitrate	mg/l as NO ₃	12
2.13	M-Alkalinity	mg/l as CaCO ₃	210
2.14	P-Alkalinity	mg/l as CaCO ₃	0
2.15	Phosphate	mg/l as PO ₄	1
2.16	Boron	mg/l as B	0.1
2.17	Reactive Silica	mg/l as SiO ₂	23
2.18	F, NH ₄ , Ba, Sr etc	mg/l as Such	If Available
Treated Water Quality			
3.01	TDS	mg/l	100
3.02	Hardness	mg/l as CaCO ₃	10
3.03	Reactive Silica	mg/l as SiO ₂	1

Before you design.. with us together!

For the given data if you wish to design together for better learning. Please:

1. Read Waughter Volume 1 Edition 7
2. Download IMS Design on your computer

Once down you will reach the WINDOW as shown below



Now follow magazine and software together.

PureCODE™

COD REDUCTION MEDIA

PureCODE is an absorbent media for the **lowering of recalcitrant COD** (Fine polishing of tough to treat COD) which subsequently helps in meeting stringent discharge norms in various industries such as textiles, chemicals, pharmaceuticals, etc. **This media is also regenerable on-site.**



PureCODE specialty media - helps in **lowering COD significantly** to meet stringent discharge norms and **recycle maximum amount of water.**


WORKING PRINCIPLES OF THE MEDIA:



ABSORPTION
(INSIDE THE MEDIA)



ADSORPTION
(SURFACE OF MEDIA)



REDOX
(OXIDATION REDUCTION)



www.purewaterent.net



+91 9820173817



info@purewaterent.net
rahul@purewaterent.net

Feed Data into Software

When we enter the data available to us, the software suggested see below: (Warning! 81% Difference in Ions). This is because Na + K is not yet entered.

We need to Click on Na to adjust the same.

Cations			Ani	
	mg/l	mg/l CaCO3		
Ca	60.00	150.00	HCO3	
Mg	24.40	100.00	S04	
Na	506.62	1101.35	Cl	
K	0.00	0.00	F	
NH4	0.00	0.00	N03	
Ba	0.000	0.00	P04	
Sr	0.000	0.00	Si02	
			B	
Total, meq/l			27.03	

Saturations	
Calculated TDS	1720 mg/l
Osmotic pressure	1.91 bar

For TDS balance designer need to increase the Cl Value as well as Na value to reach design TDS of 2310 mg/l.

It is better to have 20% extra margin wrt to TDS. Remember Osmotic Pressure is directly proportional to the Feed TDS and thus 20% over design over design value is a good practice in designing RO system.

Cations			Anions		
	mg/l	mg/l CaCO3		mg/l	mg/l CaCO3
Ca	60.00	150.00	HCO3	256.20	210.00
Mg	24.40	100.00	S04	135.00	140.63
Na	921.95	2004.23	Cl	1340.00	1889.99
K	0.00	0.00	F	0.00	0.00
NH4	0.00	0.00	N03	12.00	9.68
Ba	0.000	0.00	P04	1.00	1.58
Sr	0.000	0.00	Si02	23.00	
			B	0.10	
Total, meq/l			45.00		
			Total, meq/l		
			45.09		

Saturations	
Calculated TDS	2772 mg/l
Osmotic pressure	2.9 bar
Ca3(P04)2 SI	0.29

Cl and Na adjustment for TDS 2772 mg/l

Press **Save As** above Analysis Save and Continue...

Temperature is an important no in design (25 deg C), at higher temperature Feed Pressure reduced and quality deteriorates and vice versa.

Design the RO system?

For a proper design we have several steps that need attention, let's move 1 by 1 to all steps and understand the significance of each.

Step 1

Understand Feed Water. For TDS up-to 8000 mg/l safely take Brackish Water RO membranes and above 22000 mg/l Sea Water RO membranes.

Selection of membrane also depends upon treated water quality. For stringent quality, you may have to select High Rejection membrane. (Feed Already Entered in previous Page)

Step 2

Define Recovery. One would like to go for highest recovery. High Recovery means less volume on Reject or more concentrated Reject. That means:

- Higher Osmotic Pressure barrier and hence high Feed Pressure.
- Solubility Concerns of Ca^*HCO_3 and SiO_2
- Long Train of RO elements, remember 1st element recovers max 15% and next 15% from the balance 85% and so on...

The point c above defines no of stages. Since we have 6 Element long Pressure Tube, beyond 6 Serial no of stages increase. Let's design for 75% Recovery, i.e. 2 stages.

System Recovery	No of Elements in Series	No of Stages
40-60	6	1
60-80	12	2
80-94	18	3

Step 3

Element Diameter. Membranes are available in dia 2.5", 4" & 8". Generally, for flow rate < 200 lph we use 2.5" element and flow > 3 m³/h we use 8" element. In between it's better to use 4" element.

For special reasons or if low recovery is acceptable e.g. RO plants on boats, designer may use 8" membrane even at lower flow rates.

Step 4

Flux Selection. Flux means productivity of membrane per m² of its surface used for Filtration of clean water. Naturally it depends upon the amount (concentration) of unwanted materials. SDI usually is the measure of presence of impurities before the water is Fed to Reverse osmosis element. A sample of Flux guidelines is attached (All Membrane Suppliers issue such guidelines in their software):

Table 3.4 Design guidelines for 8-inch FILMTEC elements in water treatment applications

Feed source	RO Permeate		Well Water				Surface Supply				Wastewater (Filtered Municipal Effluent)		Seawater			
	MF ¹	Conventional	SDI < 3	SDI < 5	SDI < 3	SDI < 5	SDI < 3	SDI < 5	SDI < 3	SDI < 5	Well or MF ¹	Open intake				
Feed silt density index	SDI < 1	SDI < 3	SDI < 3	SDI < 5	SDI < 3	SDI < 5	SDI < 3	SDI < 5	SDI < 3	SDI < 5	SDI < 3	SDI < 5				
Average gfd	21-25	16-20	13-17	12-16	10-14	8-12	8-12	8-12	7-10	7-10	7-10	7-10				
system flux l/m ² h	36-43	27-34	22-29	20-27	17-24	14-20	13-20	13-20	11-17	11-17	11-17	11-17				
Maximum element recovery %	30	19	17	15	14	12	15	13	13	13	13	13				
Active Membrane Area													Maximum permeate flow rate, gpd (m³/d)			
320 R ² elements	9,000 (34)	7,500 (28)	6,500 (25)	5,800 (22)	5,300 (20)	4,700 (18)	6,700 (25)	6,100 (23)								
385 R ² elements	10,000 (38)	8,300 (31)	7,200 (27)	6,500 (25)	5,900 (22)	5,200 (20)										
380 R ² elements	10,600 (40)	8,600 (33)	7,500 (28)	6,800 (26)	6,200 (23)	5,200 (20)	7,900 (30)	7,200 (27)								
380 R ² elements	10,600 (40)	8,900 (34)	7,700 (29)	7,000 (26)	6,300 (24)	5,500 (21)										
400 R ² elements	11,000 (42)	9,100 (34)	7,900 (30)	7,200 (27)	6,400 (24)	5,700 (22)										
440 R ² elements	12,000 (45)	10,000 (38)	8,700 (33)	7,900 (30)	7,100 (27)	6,300 (24)										
Element type													Minimum concentrate flow rate², gpm (m³/h)			
BW elements (365 ft ²)	10 (2.3)	13 (3.0)	13 (3.0)	15 (3.4)	16 (3.6)	18 (4.1)										
BW elements (400 ft ² and 440 ft ²)	10 (2.3)	13 (3.0)	13 (3.0)	15 (3.4)	18 (4.1)	20 (4.6)										
NF elements	10 (2.3)	13 (3.0)	13 (3.0)	15 (3.4)	18 (4.1)	18 (4.1)										
Full-fit elements	25 (5.7)	25 (5.7)	25 (5.7)	25 (5.7)	25 (5.7)	25 (5.7)										
SW elements	10 (2.3)	13 (3.0)	13 (3.0)	15 (3.4)	16 (3.6)	18 (4.1)	13 (3.0)	15 (3.4)								
Element type													Active area		Maximum feed flow rate², gpm (m³/h)	
BW elements	365 (33.9)	65 (15)	65 (15)	63 (14)	58 (13)	52 (12)	52 (12)									
BW or NF elements	400 (37.2)	75 (17)	75 (17)	73 (17)	67 (15)	61 (14)	61 (14)									
NF elements	440 (40.9)	75 (17)	75 (17)	73 (17)	67 (15)	61 (14)	61 (14)									
Full-fit elements	390 (36.2)	85 (19)	75 (17)	73 (17)	67 (15)	61 (14)	61 (14)									
SW elements	320 (29.7)	65 (15)	65 (15)	63 (14)	58 (13)	52 (12)	52 (12)	63 (14)	56 (13)							
SW elements	380 (35.3)	72 (16)	72 (16)	70 (16)	64 (15)	58 (13)	58 (13)	70 (16)	62 (14)							

¹ MF: Microfiltration - continuous filtration process using a membrane with pore size of <0.5 micron.
² The maximum recommended pressure drop across a single element is 15 psid (1bar) or 50 psid (3.5 bar) across multiple elements in a pressure vessel, whichever value is more limiting. We recommend designing at maximum of 80% (12 psid) for any element in a system.
 Note: The limiting values listed above have been incorporated into the ROSA (Reverse Osmosis System Analysis) software. Designs of systems in excess of the guidelines results in a warning on the ROSA printout.

In our case let's take Borewell water treated with conventional sand filter and select the flux as 28 l/m².h (range 27 -34 l/m².h)

Step 5

Membrane Area Calculation. Since we have flow rate as 25 m³/h and we have selected flux as 28 l/m².h, her membrane Area required for our design is:

$$\begin{aligned} \text{Membrane Area} &= \text{Flow} \div \text{Flux} \\ &= 25000 \text{ lph} \div 28 \text{ l/m}^2.\text{h} \\ &= 892 \text{ m}^2 = 9607 \text{ ft}^2 \end{aligned}$$

So, our design shall have X Nos of membrane with Y ft² surface each membrane

and X.Y = 9607 ft²

Step 6

Membrane Selection. In step 3 we understand 8” dia membrane is good for our design since flow rate is 25 m3/h.

Element type	
BW elements (365 ft²)	10
BW elements (400 ft² and 440 ft²)	10
NF elements	10
Full-fit elements	25
SW elements	10

Element type	Active area ft² (m²)
BW elements	365 (33.9)
BW or NF elements	400 (37.2)
BW elements	440 (40.9)
Full-fit elements	390 (36.2)
SW elements	320 (29.7)
SW elements	380 (35.3)

* MF: Microfiltration - continuous filtration process
 † The maximum recommended pressure drop value is more limiting. We recommend design pressure drop to be less than this value.
 Note: The limiting values listed above have been based on the design guidelines results in a warning on the R

Close look of chart in Step 4 above suggests we have different elements with different active surface area. So let consider the membrane with Active Area of ~ 365 ft2

So our Nos of membranes required shall be

$$= 9607 \div 365 = 26.32$$

~ say 27


Step 7

RO Pressure Tubes. The 27 Nos membrane calculated above need to be put into pressure tubes. The standard length of the tubes are 1,2,3,4,5 & 6.

Further in Step 2 we understand the Nos of stage shall be 2. i.e. Reject of Stage 1 shall be Fed to Stage 2.

If we select 6 Element Pressure Tube, we will need 6*5 = 30 membranes to fill all pressure tubes. If we select 5 Element Tube then we will need 5*6 = 30 membranes to fill all pressure Tubes.

In short Total no of membranes used ÷ No of Elements in Tube shall be a whole number. Let’s select the Pressure Tube length as 5 El Long, means 6 Pressure Tube. Like below:




6 * 5 = 30
 membranes filled
 in 6 Pressure
 Tubes that are
 each 5 El long.

Step 8

Staging Ratio. No of stages we selected depends upon recovery and for 75% we selected 2. The last stage shall always have ½ the element of previous stage. So for a two stage system:

$$\begin{aligned} \text{No of membranes in last stage (2}^{nd}\text{)} &= A \\ \text{No of membranes in previous stage (1}^{st}\text{)} &= 2A \end{aligned}$$




Thus 3A = 30 and A = 10. So our Staging would be as shown above. Here one can say that ~ 50% recovery is achieved in stage 1 and 50% of 50% balance that is ~ 25% is recovered in stage 2 making overall recovery as ~ 75%.

Final 25% is reject water that is removing TDS that has been rejected by membrane.

Step 9

For 9th step, we need to understand the word “Integral Calculations”, Look at below Pressure Tube and understand what’s happening when water is flowing:



- Feed Flow is decreasing and becomes 5 m³/h at end as some of it becomes permeate.
- Osmotic Pressure keeps increasing as TDS becomes 1950 from starting 1000 mg/l
- Since Feed Pressure say ~ 12 kg/Cm², will keep reducing, NDP (Nett Drive Pressure = Feed Pr – Osmotic Pr) will decrease.
- Thus, the Permeate production shall decrease as we travel down the tube means 1st element will produce most of the permeate and last the least.
- Bottom line: Flux is always reducing.

Step 10

Software Use. The design obtained from above 9 steps is transported on a software to perform calculations and check if the guidelines for membrane use are violated. One must balance the flow (Flux) to ensure:

- Lead Element flux is not higher than the limit set.
- Brine leaving from last element should not be lower than defined value, else scaling/fouling. Minimum Sweep velocity to be maintained.
- Make better use (Flux) of tail end elements
- Many more reasons as we learn along

Our design as entered in software shall look as in below figures.

- Press Run to check if design is OK, the calculations are performed and we have:
 - Beta High 1.21 marked in Red
 - TDS < 63 mg/l as per our design.

Array	Vessels	Feed (bar)	Conc (bar)	Feed (m3/h)	Conc (m3/h)	Flux (lmh)	Highest flux (lmh)	Highest beta
1-1	4	12.8	11.9	8.33	3.36	29.4	34.3	1.21
1-2	2	11.7	11	6.71	4.16	15.1	20.0	1.10

To correct Beta, reduce recovery and enter correct membrane age as 3 years, we get final design as:


Array	Vessels	Feed (bar)	Conc (bar)	Feed (m3/h)	Conc (m3/h)	Flux (lmh)	Highest flux (lmh)	Highest beta
1-1	4	13.9	12.9	8.56	3.74	28.5	32.4	1.19
1-2	2	12.7	11.9	7.48	4.61	17	21.0	1.10

The Screen shot of data entry, please mark membrane age 0 is a wrong entry it must be 3.

- Concentrate Recirculation is a way to increase recovery and control Beta Factor (Higher flow from lead element)
- Booster Pump design is to ensure better flux distribution through-out membrane train and energy optimization
- Permeate Back Pressure design controls higher flow from lead elements. Can pose engineering challenge while construction, be careful.

Final Design

The Final design thus has 73% recovery, TDS < 70 mg/l and designer can take a complete 3 page print to see the design and performance of each element.



The PDF of 1st page of design is of interest wrt to solubility points:

Integrated Membranes Solutions Design Software
Created on: 7/11/2022 03:59:40

Nitto HYDRANAUTICS
NITTO Group Company

Basic Design

Project name: Waughter Vol 2 Edi 6
Calculated by: Vrushika Parmar

Permeate flow/train: 25.00 m³/h
Raw water flow/train: 34.25 m³/h
Permeate recovery: 73.00 %
Element age: 3.0 years
Flux decline %, per year: 0.86
Fouling factor: 7.0 %
SP increase, per year: 0.207 bar
Inter-stage pipe loss: 24.5 mm

Pass - Stage	Perm. Flow m ³ /h	Flow / Vessel m ³ /h	Feed Conc m ³ /h	Flux lmh	DP bar	Flux Max lmh	Beta	Stagewise Perm. bar	Pressure Boost bar	Permeate Conc mg/l	Element Type	Element Quantity	PV# x Elem #
1-1	19.3	8.6	3.7	28.5	0.9	32.4	1.19	0	0	12.9	CPA2	20	4 x 5M
1-2	5.7	7.5	4.6	17	0.9	21	1.1	0	0	11.9	CPA2	10	2 x 5M

Ion (mg/l)	Raw Water	Feed Water	Permeate Water	Concentrate 1	Concentrate 2
Hardness, as CaCO ₃	250.00	250.00	0.00	572.3	927.7
Ca	60.00	60.00	0.031	137.4	222.6
Mg	24.40	24.40	0.013	55.9	90.5
Na	921.95	921.95	25.113	2091.5	3354.4
K	0.00	0.00	0.000	0.0	0.0
NH ₄	0.00	0.00	0.000	0.0	0.0
Ba	0.000	0.000	0.000	0.0	0.0
Sr	0.000	0.000	0.000	0.0	0.0
H	0.00	0.00	0.000	0.0	0.0
CO ₂	1.62	1.62	0.002	9.7	27.2
HCO ₃	256.20	256.20	10.565	568.0	889.3
SiO ₂	135.00	135.00	0.786	308.5	499.0
Cl	1340.00	1340.00	30.555	3044.1	4990.5
F	0.00	0.00	0.000	0.0	0.0
NO ₃	12.00	12.00	1.946	26.9	39.3
PO ₄	1.00	1.00	0.056	2.3	3.7
OH	0.01	0.01	0.001	0.0	0.0
SiO ₂	23.00	23.00	0.452	52.3	84.2
B	0.10	0.10	0.089	0.1	0.1
CO ₂	5.42	5.42	5.42	5.42	5.42
NH ₃	0.00	0.00	0.00	0.00	0.00
TDS	2775.26	2775.26	68.96	6295.76	10100.96
pH	7.80	7.80	6.48	8.12	8.29


Saturations	Raw Water	Feed Water	Concentrate	Limits
CaSO ₄ / ksp * 100, %	1	1	6	400
SrSO ₄ / ksp * 100, %	0	0	0	1200
BaSO ₄ / ksp * 100, %	0	0	0	10000
SiO ₂ saturation, %	17	17	65	140
CaF ₂ / ksp * 100, %	0	0	0	50000
Ca ₃ (PO ₄) ₂ saturation index	0.3	0.3	1.4	2.4
CCPP, mg/l	14.01	14.01	283.64	850
Langmuir saturation index	0.27	0.27	1.81	2.8
Ionic strength	0.05	0.05	0.18	
Osmotic pressure, bar	2.0	2.0	7.4	

The LSI of 1.8 indicates we need to add antiscalant.

Further SiO₂ saturation is in limit so no worries, or else use antiscalant till SiO₂ in Concentrate 2 is up to 300 mg/l

For more practice and perfect your design.

जल जीवन जनी !!



Our world is Waughter

The technical knowledge share attempt of Aktion Consultancy and the contents in the magazine shall be qualified by Sanjeev Srivastava our Technology Lead.

Our next edition focuses on: "UF Design & BOQ Generation"

Please feel free to write or contact Mrs. Neha Deshpande 95129 55227

Aktion Consultancy
C 1305, Rajyash Rise
New Vasana,
Nv Vishala Circle,
NH-08,
Ahmedabad - 380 051 India



Alka Srivastava – Founder